



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

October 18, 2006

Certified Mail

Return Receipt Requested: 7005 0390 0002 1979 0420

Mr. Ashish Dhuldhoya
Polycoat Products
14722 Spring Avenue
Santa Fe, CA 90670-5108

RE: DEP Approval of the Polycoat Polyeuro 5502
coating, File No. EQ-651

Dear Mr. Dhuldhoya:

The Bureau of Petroleum Storage Systems has concluded its review of the Equipment Approval request dated September 7, 2006, that was submitted for the above referenced coatings pursuant to Rule 62-762.851, Florida Administrative Code (F.A.C.).

Based on the information provided by Polycoat Products, the Department finds that the applicant's Polycoat Polyeuro 5502 coating will provide environmental protection substantially equivalent to that provided by compliance with the requirements established in Rule 62-762.501(1)(e)3.b., F.A.C.

Pursuant to Rule 62-762.851, F.A.C., the request for the use of the above referenced product is approved in the State of Florida as a coating for concrete or steel secondary containment of aboveground storage tanks containing petroleum products. The Polycoat Polyeuro coating must be applied with a minimum of 40 mils thickness over steel or a minimum of 60 mils thickness over concrete areas and must be applied in accordance with the manufacturer's recommendations.

Please be advised that the above referenced DEP rules are subject to change. If the above rule standards are modified in the future, this Order may be modified or rescinded for future upgrades and installations. Additionally, if the product(s) shows a consistent pattern of failure(s), and therefore does not provide substantially equivalent environmental protection, the Department may rescind this Order.